

All products made-to-order.

Loaded Vinyl | Wall

Specialized

Loaded Vinyl Panels are designed to stop sound transmission through walls while absorbing the ambient noise within. Often used for speech privacy in offices, and patient consultation areas, as well as being a general sound barrier for foot traffic or industrial noise

Items to specify













Hotmelt fabric adhesion

Provides superior bond strength lasting the lifetime of the product, Easily reactivated for field repairs and modification.





Core thickness

15/8" 2 1/8"

Dimensions

Height: Min of 12 inches and max of 48 inches. Length: Min of 12 inches and max of 96 inches. Maximum Size: 16 square feet.

Fabric finish

Carnegie kvadrat Guilford of Maine **DesignTex** Knoll maharam

Click for Word specsheet

SECTION 098413 ► FIXED SOUND-ABSORPTIVE PANELS

PART 1—GENERAL

1.1—SUMMARY

A. Section includes:

Fixed sound-absorptive panels.

B. Related work:

The following items are not included in this Section and are specified under the designated Sections: Section 092100 - PLASTER AND GYPSUM BOARD ASSEMBLIES for plaster and gypsum board walls and ceilings.

1.2—SUBMITTALS

A. Product data:

Submit manufacturer's product data including certified laboratory test reports and other data required to show compliance with these specifications.

Submit 8 ¾ x 11 inch (for thicknesses up to 1 ½ inches) or 11 ½ x 11 ½ inch (for thicknesses larger than 1 ½ inches) samples of representative panel with factory detailed edge, and representative samples of mounting devices.

1.3—QUALITY ASSURANCE

A. Pre-installation conference:

Conduct conference at Project site to comply with requirements in Division 01.

1.4—DELIVERY, STORAGE, AND HANDLING

Protect system components from excessive moisture in shipment, storage, and handling. Deliver in unopened bundles and store in a dry place with adequate air circulation. Do not deliver material to building until wet conditions such as concrete, plaster, paint, and adhesives have been completed and cured to a condition of equilibrium.

1.5—LIMITED WARRANTY

A. Limited warranty:

Provide manufacturer's standard limited 3-year warranty against manufacturing defects in material or workmanship.

PART 2—PRODUCTS

2.1—SOUND ABSORPTIVE PANELS:

A. Basis-of-Design: Conwed Loaded Vinyl | Wall

Formerly known as Conwed Loaded Vinyl Wall Panels

- Construction: Composite core construction of dimensionally stable rigid fiberglass backed by 1/8 inch loaded vinyl barrier, fully adhered to fiberglass.
- Fiberglass density: 6 7 pcf.
- Provide optionally laminated cores with 1/8 inch thick, 16 20 pcf molded fiberalass.
- Recycled content: For fiberglass, 52 percent pre-consumer and 5 percent post-consumer recycled content.
- 5 Core thickness: 11/8 inch.
- 6. Core thickness: 15/8 inches.
- Core thickness: 2 1/8 inches.
- Width: 12 to 48 inches. 8.
- Length: 12 to 96 inches.
- 10. Max size is 16 square feet.
- 11. Corners: Square.
- 12. Edge profile: Square.
- 13. Edge profile: Radius.
- 14. Edge profile: Bevel.
- 15. Edge treatment: Resin hardened.
- **16.** Edge treatment: Aluminum for square edge only.
- 17. Edge treatment: High-pressure laminate, for square edge only.
- 18. Fabric adhesion: Conwed HotMelt is standard for bonding fabric to the substrate.
- 19. Fabric finish: Manufacturer, pattern and color as selected; applied directly over face and edges of panels to provide full finished edge, fully tailored corners.
- 20. Fabric Adhesion: Conwed Hotmelt is standard for bonding fabric to the substrate.
- 21. Mounting type: Z-Bar to Z-Bar.
- 22. Flammability (ASTM E 84): Panel components shall have a Class "A" rating per ASTM E 84.
- 23. Resistivity to heat or cold: R-factor of 4.16 per inch of thickness.
- 24. Acoustical performance: Values below are for panels mounted in accordance with ASTM C 423 (Type D5 Mounting) and vary by panel thickness and finish.
 - a. Noise reduction coefficient (NRC) for 1 1/8 inch thickness: —.
 - b. Noise reduction coefficient (NRC) for 15/8 inch thickness: —.
 - c. Noise reduction coefficient (NRC) for 2 1/8 inch thickness: —.

PART 3—EXECUTION

3.1—INSTALLATION:

- A. Verify wet work such as plastering and concrete is complete and dry. Verify building is enclosed and under standard occupancy conditions (60 - 85°F and not more than 70% relative humidity) prior to start of installation. Commencement of installation constitutes Installer's acceptance of surfaces and conditions.
- B. Install products in accordance with manufacturer's written instructions and in proper relationship with adjacent construction.
- C. Touch-up, repair or replace damaged units until satisfactory results are obtained.

PROJECT ARCHITECT RESPONSIBILITY >

This is a general specification guide, intended to be used by experienced construction professionals, in conjunction with good construction practice and professional judgment. This guide is to aid in the creation of a complete building specification that is to be fully reviewed and edited by the architect of record (specifier). Sections of this guide should be included, edited, or omitted based on the requirements of a specific project. It is the responsibility of both the specifier and the purchaser to determine if a product or system is suitable for its intended use. Neither Conwed, nor any of its subsidiary or affiliated companies, assume any responsibility for the content of this specification quide relative to actual projects and specifically disclaim any and all liability for any errors or omissions in design, detail, structural capability, attachment details, shop drawings or other construction related details, whether based upon the information provided by Conwed or otherwise

