

All products made-to-order.



# Wall Panel | Copolymer


Product

# Durability

Conwed Panels are reliable, all-purpose acoustic solutions. Capable of multiple levels of durability, highly-customizable finishes, and mounting options, this product is suitable for schools, auditoriums, theaters, offices, and libraries: anywhere noise control is needed.

Metro Rebound

# Items to specify







Conwed Rotofast EZ-clips Pre-installed mounting points for engaging Z-bars with depth adjustability. Easy to move and adjust if required.



to z-bar

7-clip

to dw

bracket



Resin



Z-bar

to z-bar

Rotofast

# Snap-on

### Core thickness

1%16"

#### Corners



Square

#### Edge profile



Sauare

Heat-formed copolymer, square edges.

#### **Dimensions**

Height: Max of 60 inches or custom. Length: Max of 144 inches or custom. Maximum Size: For thickness of 4 inches, max of 24 square feet.



Highly durable finish that comes in standardized and custom colors

Click for Word specsheet

# **SECTION 098413** ► FIXED SOUND-ABSORPTIVE PANELS

## PART 1—GENERAL

#### 1.1 — SUMMARY

A. Section includes:

Fixed sound-absorptive panels.

B. Related work:

The following items are not included in this Section and are specified under the designated Sections: Section 092100 - PLASTER AND GYPSUM BOARD ASSEMBLIES for plaster and gypsum board walls and ceilings.

#### 1.2 — SUBMITTALS

A. Product data:

Submit manufacturer's product data including certified laboratory test reports and other data required to show compliance with these specifications.

Submit  $83/4 \times 11$  inch (for thicknesses up to 11/2 inches) or  $111/2 \times 111/2$  inch (for thicknesses larger than 11/2 inches) samples of representative panel with factory detailed edge, and representative samples of mounting devices.

#### 1.3 — QUALITY ASSURANCE

A. Pre-installation conference:

Conduct conference at Project site to comply with requirements in Division 01.

#### 1.4 — DELIVERY, STORAGE, AND HANDLING

Protect system components from excessive moisture in shipment, storage, and handling. Deliver in unopened bundles and store in a dry place with adequate air circulation. Do not deliver material to building until wet conditions such as concrete, plaster, paint, and adhesives have been completed and cured to a condition of equilibrium.

#### 1.5 — LIMITED WARRANTY

A. Limited warranty:

Provide manufacturer's standard limited 3-year warranty against manufacturing defects in material or workmanship.

1

#### 2.1 — SOUND ABSORPTIVE PANELS:

#### A. Basis-of-Design: Conwed Wall Panel | Copolymer | HI

Formerly known as Conwed Metro Rebound Wall Panel

- Construction: Composite core construction of dimensionally stable rigid fiberglass.
- Fiberglass Density: 6-7 pcf. 2.
- 3. Core laminated with a 1/16 inch, resilient perforated copolymer face sheet.
- Recycled content: For fiberglass, 52 percent pre-consumer and 5 percent post-consumer recycled content.
- 5. Core thickness: 1 1/16 inches. Core thickness: 1 9/16 inches. 6. Core thickness: 2 1/16 inches.
- Height: Max of 48 inches and custom. 8.
- Length: Max of 116 inches and custom.
- 10. Corners: Square. 11. Edge profile: Square.
- Finish: Copolymer applied directly to face and edges of panels, color as selected.
- **13.** *Mounting type:* Z-Clips to Z-Bar. 14. Mounting type: Z-Clip to DW Bracket.
- 15. Mounting type: Z-Bar to Z-Bar. 16. Mounting type: Resin spots.
- 17. *Mounting type:* Rotofast<sup>™</sup> Snap-on Anchors. **18.** *Mounting type:* Conwed Rotofast™ EZ-Clips.
- 19. Flammability (ASTM E 84): Panel components shall have a Class "A" rating per ASTM E 84.
- 20. Resistivity to heat or cold: R-factor of 4.16 per inch of thickness.
- 21. Acoustical performance: Values below are for panels mounted in accordance with ASTM C 423 (Type D5 Mounting) and vary by panel thickness and finish.
  - a. Noise reduction coefficient (NRC) for 11/16 inch thickness: 0.80.
  - b. Noise reduction coefficient (NRC) for 2 1/16 inch thickness: 0.95.

## PART 3—EXECUTION

#### 3.1 — INSTALLATION:

- A. Verify wet work such as plastering and concrete is complete and dry. Verify building is enclosed and under standard occupancy conditions (60-85°F and not more than 70% relative humidity) prior to start of installation. Commencement of installation constitutes Installer's acceptance of surfaces and conditions.
- B. Install products in accordance with manufacturer's written instructions and in proper relationship with adjacent construction.
- C. Touch-up, repair or replace damaged units until satisfactory results are obtained.

# PROJECT ARCHITECT RESPONSIBILITY >

This is a general specification guide, intended to be used by experienced construction professionals, in conjunction with good construction practice and professional judgment. This guide is to aid in the creation of a complete building specification that is to be fully reviewed and edited by the architect of record (specifier). Sections of this guide should be included, edited, or omitted based on the requirements of a specific project. It is the responsibility of both the specifier and the purchaser to determine if a product or system is suitable for its intended use. Neither Conwed, nor any of its subsidiary or affiliated companies, assume any responsibility for the content of this specification guide relative to actual projects and specifically disclaim any and all liability for any errors or omissions in design, detail, structural capability, attachment details, shop drawings or other construction related details, whether based upon the information provided by Conwed or otherwise



v 5 0 00

©2025